



- For product which is not in the original carton the 10kA rating can be identified as shown below. There is a date code on the MCB located on the top surface above the grey actuator. This relates to the week of manufacture as shown below:



10kA Rating



27 is the week of manufacture,  
16 is the year




If the code is shown on the table below, then please return stock to Hager.

GE2716	GE2816	GE2916	GE3016	GE3116	GE3216
GE3316	GE3416	GE3516	GE3616	GE3716	GE3816

MCU63 View



SBM# View



INVESTOR IN PEOPLE